




GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



FORM - (G)
No. F&ES/FPW/18(XVI) 1125/21

Dated Guwahati the 28/7/21

The Chairman,
Marry's Public School,
Kabaitari, Jogighopa,
Dist:- Bongaigaon, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE MARRY'S PUBLIC SCHOOL AT KABAITARI, JOGIGHOPA, DIST:- BONGAIGAON, ASSAM.

With reference to your completion report under No. **NIL** Dated **16.06.2021** and on the basis of the inspection report submitted by Response Team Commander, Amit Barman on the building as per description below at Dag No. **395** Patta No. **69** Mouza **Jogighopa**, (Place- **Jogighopa, Kabaitari**) in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention/ means of escape measures as declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of **SCHOOL** subject to condition mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-


GROUND FLOOR:-
1. Floor area: - **400 ft²**
2. Purpose of utilization: -
For School Purpose.

FIRST FLOOR:-
1. Floor area: - **400 ft²**
2. Purpose of utilization: -
For School Purpose.

SECOND FLOOR:-
1. Floor area: - **400 ft²**
2. Purpose of utilization: -
For School Purpose.

Details of Fire Fighting measures found in working condition:

1. Hose Reel Hose system
2. Down Comer System
3. Manually Operated Electric Fire Alarm system,
4. Fire Extinguishers-8 Nos.
5. Terrace Water Tank
6. Terrace Pump


Deputy Director,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.
Dated Guwahati the _____

NO. F&ES/FPW/
Copy to:-

1. The Deputy Commissioner, **Bongaigaon**, Assam for information and necessary action.
2. The Chairman, **Bongaigaon Municipal Board**, Assam for information and necessary action.
3. The Response Team Commander, **Bongaigaon F&ES Station**, for information.

Deputy Director,
for and on behalf of

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2022.**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.
4. There should not also be any change in the existing arrangements.
5. The Fire Fighting equipments should be in serviceable condition at all time.
6. Water reservoir should always be kept full up to brim.
7. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
8. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

Deputy Director,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.